

**CENTRAL POWER RESEARCH INSTITUTE
(MEMBER STL)**



CPRI

TEST REPORT

Test Report Number : No.43/1/2014-HV/2892/PC/1289 **Dated:** 23/12/2014

Name & Address of the customer : M/s. Pragathi Controls
No. 9/16, 4th main, Yelechanahalli,
J.C Industrial area, Kanakapura Road,
Bangalore-560062.
Ref: Nil **Dated:** 11/12/2014

Name & Address of the Manufacturer : M/s. Pragathi Controls
No. 9/16, 4th main, Yelechanahalli,
J.C Industrial area, Kanakapura Road,
Bangalore-560062.


Particulars of Samples tested
Condition of the sample on Receipt : New.
Type : Indoor.
Designation : 11kV, 1250A, HT Panel without VCB.
Serial Number : 094690.
Number of samples tested : One.
Date(s) of Test(s) : 12/12/2014.
CPRI Sample Code Number : SC14 S1463.

Particulars of tests conducted : 1. Lightning Impulse Voltage Test Clause-6.2.6.2
2. Power Frequency Voltage Test (Dry) Clause-6.2.6.1


Test in accordance with standard/ Specification. : As per IEC 62271-200/2011-10 Ed. 2.0.
Sampling Plan : Not Applicable.
Customer's requirement : Test Voltage for both open and closed condition.
Deviations if any : Nil.

Name of the witnessing persons
Customer's representatives : Shri. K.N.Muralli.
Other than customer's representatives : None.
Test subcontracted with Address of the laboratory : None.

Documents constituting this report(in words)
Number of sheets : Three.
Number of oscilogram/s : Twelve.
Number of graphs : Nil.
Number of photo/s : Nil.
Number of Test Circuit Diagrams : Nil.
Number of drawings : Four. {Drawing Nos. 1) PC/CR/13913/14 Rev 01 Sheet 1 of 5
2) PC/CR/13913/14 Rev 01 Sheet 2 of 5
3) PC/CR/13913/14 Rev 01 Sheet 3 of 5
4) PC/CR/13913/14 Rev 01 Sheet 5 of 5}.


(PRIYA S) 23/12/2014
Test Engineer




(Dr.N.VASUDEV)
Joint Director & HOD

Sheet 1 of 3