

CENTRAL POWER RESEARCH INSTITUTE

TEST REPORT



CPRI

Test Report Number: 244EATDIP15S0225

Dated: 24.08.2015

Name & Address of the Customer : M/s. Pragathi Controls
No. 9/16, 4th Main, JC Industrial Layout, Yelachenahalli,
Kanakapura Road, Bengaluru – 560 062.

Name & Address of the Manufacturer : M/s. Pragathi Controls
No. 9/16, 4th Main, JC Industrial Layout, Yelachenahalli,
Kanakapura Road, Bengaluru – 560 062.

Particulars of sample tested

Condition of the sample on Receipt : New.
Type : Outdoor.
Designation : Main LT Panel.
Serial Number : 95648.
Number of samples tested : One only.
Date (s) of Test (s) : 20.08.2015 and 21.08.2015
CPRI sample code no(s) : EATDIP15S0225

Particulars of tests conducted


Test in accordance with : IP 55 Test Category 2 as per IEC 60529 Edition 2.2,
Standard / specification : 2013-08 Standard. Clause 11.5, 13.4 and 14.2.5.
Sampling Plan : Not applicable
Customer's requirement : 1. IP 55 Test Category 2 as per IEC 60529 Edition 2.2,
2013-08 Standard. Clause 11.5, 13.4 and 14.2.5.
2. Visual observation of entry of Dust (IP 5X) and Water (IP X5)
only.
Deviations if any : -Nil-

Name of the witnessing persons


Customer's representative : Mr. K.N. Murali, Manager. (M/s. Pragathi Controls)
Mr. Yogesh, Engineer. (M/s. Pragathi Controls)
Other than customer's representatives : None
Test subcontracted with address of the laboratory : None

Documents constituting this report (In words)

Number of sheets : Three Only
Number of oscillograms : -Nil-
Number of graphs : -Nil-
Number of photos : -Nil-
Number of test circuit diagrams : -Nil-
Number of drawing : Two only. Drg. No. PC/CR/15334/15, REV 00,
SHEET 1 of 3, SHEET 2 of 3 and SHEET 3 of 3.


(GUJJALA B. BALARAJU)
Test Engineer 26/08/15




(M. SIDDHARTHA BHATT)
Additional Director